

Warringtonfire Holmesfield Road Warrington WA1 2DS T: +44 (0)1925 655 116 info.warrington@warringtonfire.com warringtonfire.com

Title:

CLASSIFICATION OF REACTION TO FIRE PERFORMANCE IN ACCORDANCE WITH EN 13501-1:2018.

Notified Body No:

0833

Product Name:

"BACE-LINETM 6.3M"

Report No:

WF 417973

Issue No:

1

Prepared for:

Elite Crete Systems

1151 Transport Drive Valparaiso IN 46383

Date:

21st October 2019



1. Introduction

This classification report defines the classification assigned to "BACE-LINETM 6.3M", a self levelling concrete, in accordance with the procedures given in EN 13501-1:2018.

2. Details of classified product

2.1 General

The product, "BACE-LINE[™] 6.3M", is defined as being suitable for floorcovering applications.

2.2 Product description

The product, "BACE-LINE[™] 6.3M", is fully described below and in the test reports provided in support of classification listed in Clause 3.1.

General description		Self-levelling concrete applied to cement board		
		substrate		
Product reference		"BACE-LINE [™] 6.3M"		
Name of manufactu	Irer	Elite Crete Systems		
Thickness		12.7mm (Stated by sponsor)		
		13.59mm (determined by Warringtonfire)		
Weight per unit area		25.52kg/m ² (determined by Warringtonfire)		
	Generic type	Self-levelling concrete overlay		
	Product reference	"BACE-LINE [™] 6.3M"		
	Name of manufacturer	Elite Crete Systems		
	Colour reference	"Grey"		
Coating	Number of coats	One		
Coating	Thickness per coat	6.35mm		
	Specific gravity	2875g/l		
	Application method	Gauge raked, then allowed to flow		
	Curing process per coat	Ambient temperature cure		
	Flame retardant details	See Note 1 below		
	Generic type	Cement backer board		
	Product reference	"HardieBacker ^{™"}		
Substrate	Detailed description	Cement/sand mix		
	Name of manufacturer	JamesHardie [™]		
	Thickness	6.35mm		
	Density	See Note 2 below		
	Colour reference	"Grey"		
	Flame retardant details	See Note 2 below		
Brief description of manufacturing process		Self-levelling cement mix applied to substrate; raked and self-levelled		

- Note 1: The sponsor of the test has confirmed that no flame retardant additives were utilised in the production of the product.
- Note 2: The sponsor was unable to provide this information.

3. Test reports & test results in support of classification.

3.1 Test reports.

Name of Laboratory	Name of sponsor	Test reports/extended application report Nos.	Test method / extended application rules & date	
warringtonfire	Elite Crete Systems	WF 417937	EN ISO 11925-2	
warringtonfire	Elite Crete Systems	WF 417932	EN ISO 9239-1	

3.2 Test results

Test method & test number		Parameter	No. tests	Results	
				Continuous parameter - mean (m)	Compliance with parameters
EN ISO 9239-1		Critical flux	3	≥11.0 kW/m²	Compliant
		Smoke		1.37 %min	Compliant
11925-2	(15s exposure – surface of decorative face)	Fs	6	Nil	Compliant
		Flaming droplets/ particles		None	Compliant
EN ISO 11925-2	(15s exposure – edge of decorative face)	Fs	6	Nil	Compliant
		Flaming droplets/ particles		None	Compliant

4. Classification and field of application

4.1 Reference of classification

This classification has been carried out in accordance with clause 9 of EN 13501-1:2018.

4.2 Classification

The product, "BACE-LINETM 6.3M", a self levelling concrete, in relation to its reaction to fire behaviour is classified:

Bfl

Page 4 of 4

The additional classification in relation to smoke production is:

s1

The format of the reaction to fire classification for floorings is:

Fire Behaviour		Smoke Production		
BFL	-	S	1	

i.e. B_{FL} – s1

Reaction to fire classification: B_{FL} – s1

4.3 Field of application

This classification is valid for the following end use applications:

i) Floorcovering applications as constructed

This classification is also valid for the following product parameters:

Coating / substrate thicknessNo variatieCoating / substrate weight per unit areaNo variatieCoating / substrate compositionNo variatieFloorcovering constructionNo variatieColour/PatternAny variatie

No variation allowed No variation allowed No variation allowed Any variation allowed

APPROVED

5. Limitations

This document does not represent type approval or certification of the product.

SIGNED

Matthew Dale Senior Certification Engineer Technical Department

Pannel Van

Janet Murrell Technical Manager Technical Department on behalf of warringtonfire

This version of the report has been produced from a .pdf format electronic file that has been provided by **Warringtonfire** to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of **Warringtonfire**.

All work and services carried out by Warringtonfire Testing and Certification Limited are subject to, and conducted in accordance with, the Standard Terms and Conditions of Warringtonfire Testing and Certification Limited, which are available at <u>https://www.element.com/terms/terms-and-conditions</u> or upon request.